



Instruction manual

Flow Sensor

VA 550



I. Foreword

Dear customer,
thank you very much for deciding in favour of the VA 550. Please read this installation and operation manual carefully before mounting and initiating the device and follow our advice. A riskless operation and a correct functioning of the VA 550 are only guaranteed in case of careful observation of the described instructions and notes



Sales Office South / Geschäftsstelle Süd

Zindelsteiner Str. 15
D-78052 VS-Tannheim
Tel.: +49 (0) 7705 978 99 0
Fax: +49 (0) 7705 978 99 20
Mail: info@cs-instruments.com
Web: <http://www.cs-instruments.com>

Sales Office North / Geschäftsstelle Nord

Am Oker 28c
D-24955 Harrislee
Tel.: +49 (0) 461 700 20 25
Fax: +49 (0) 461 700 20 26
Mail: info@cs-instruments.com
Web: <http://www.cs-instruments.com>

II. Table of Content

I.	Foreword	2
II.	Table of Content.....	3
1	Pictograms and Symbols	5
2	Signalwords according ISO 3864 and ANSI Z 535	5
3	Safety instructions	6
3.1	Intended Use.....	7
3.2	Installation and commissioning.....	7
4	Technical data	8
4.1	Signal circuits	9
4.1.1	Modbus	9
4.1.2	Current output.....	9
4.1.2.1	Aktive	9
4.1.2.2	Passive	9
4.1.3	Pulse.....	9
4.1.4	Alarm	9
4.2	Measuring range flow VA 550.....	10
4.2.1	Measuring range „Standard Version“	11
4.2.2	Measuring range „Max Version“	13
4.2.3	Measuring range „High Speed Version“	15
5	Dimensions.....	17
5.1	Dimension VA 550	17
6	Installation	18
6.1	Pipe/tube requirements.....	18
6.2	Inlet / outlet runs.....	18
6.3	Installation VA 550	19
6.3.1	½“ welded nipple with ball valve ½“	19
6.3.2	Spot drilling collar with ball valve.....	19
6.4	Installation of the Sensor	20
6.4.1	Mounting VA 550 onto the ball valve	20
6.5	Alignment Display (Housing).....	21
6.6	Tightening torques	21
7	Connection diagram	22
7.1	Cable glands - clamping ranges	22
7.2	Connector pin assignment	22
7.3	Wire connection	24
7.3.1	General:	24
7.3.2	Power supply	24
7.3.3	Modbus RTU:.....	24
7.3.4	Modbus TCP (Ethernet) Optional PoE	25
7.3.5	Pulse Output.....	25
8	Operation VA 550.....	26

8.1	Main menu (Home)	27
8.1.1	Intialization.....	27
8.2	Main menu	27
8.3	Settings	28
8.3.1	Sensor Setup.....	29
8.3.1.1	Input / change tube diameter	29
8.3.1.2	Input / change consumption counter	30
8.3.1.3	Definition of the units for flow, velocity, temperature and pressure.....	30
8.3.1.4	Definition of the reference conditions	31
8.3.1.5	Setting of Zeropoint and Low-flow cut off	33
8.3.2	Modbus RTU.....	34
8.3.2.1	Setup	34
8.3.3	Modbus TCP (Optional).....	35
8.3.3.1	Setup	35
8.3.3.1.1	Network Setup DHCP	35
8.3.3.1.2	Network Settings static IP	36
8.3.3.1.3	Modbus TCP Settings.....	37
8.3.3.2	Modbus Settings (2001...2005).....	38
8.3.3.3	Values Register (1001 ...1500)	38
8.3.4	Pulse /Alarm	40
8.3.4.1	Pulse output.....	40
8.3.5	User Setup.....	41
8.3.5.1	Password	41
8.3.5.2	Language.....	41
8.3.5.3	Display / Touch.....	42
8.3.6	Advanced.....	42
8.3.7	4 -20mA	43
8.3.8	VA 550 Info	45
8.4	MBus	46
8.4.1	Change of communication settings	46
8.4.2	Coding VIF (Value Information Field)	47
8.4.3	Default Settings communication	47
8.4.4	Default values transmitted	47
9	Supplementary Documentation.....	47

1 Pictograms and Symbols



General Warning symbol (Danger, Warning, Caution)



General note



Installation- and Instruction manual to consider (on Nameplate)



Installation- and Instruction manual to consider

2 Signalwords according ISO 3864 and ANSI Z 535

Danger!	Imminent danger As a consequence of incorrect handling: serious personal injury or death
Warning!	Possible hazard As a consequence of incorrect handling: possible serious injury or death
Caution!	Imminent hazard As a consequence of incorrect handling: possible personal injury or damage
Note!	Possible hazard As a consequence of incorrect handling: possible personal injury or damage
Important!	Additional notes, information, tips As a consequence of incorrect handling: Disadvantages in operation and maintenance, no danger

3 Safety instructions

**Please check whether this manual corresponds with the device type.**

Please attend to all notes indicated in this instruction manual. It contains essential information, which has to be followed during installation, operation and maintenance. Therefore this instruction manual has to be read categorically by the technician as well as by the responsible user/qualified personnel before installation, initiation and maintenance

Regional and national regulations respectively, have to be observed in addition to this instruction manual if necessary.

This instruction manual has to be available at any time at the operation site of the VA 550.

Ensure that the VA 550 operates within the permissible and listed limits on the nameplate. Otherwise there is a risk to human and material, and it may occur functional and operational disturbances

In case of any obscurities or questions with regard to this manual or the instrument please contact CS Instruments GmbH..

**Warning!****Risk of injury in case of inadequate qualification!**

Improper handling can result in significant personal injury and damage.

All activities described in this operating instructions manual must be carried out only by qualified personnel qualifications described below.

Professionals (Technical staff)

The technical staff is based on his education/training, his knowledge of measurement and control technology as well of the local regulations, standards and guidelines in the position to do the work as described and to identify the possible hazards.

Special working conditions require further appropriate knowledge, e.g. of aggressive media.

**Caution!****Malfunction of VA 550**

Faulty installation and insufficient maintenance may lead to malfunctions of the VA 550 which may affect the display and open to misinterpretation.

**Danger!****Inadmissible operating parameters!**

By exceeding or falling short of limits there is a risk for people and material, in addition there may occur further functional and operational disturbances.

Measures:

- Make sure that the VA 550 operates only within the permissible and listed limits on the nameplate
- Ensure the operation within the performance data of VA 550 in connection with the application
- Do not exceed the admissible storage and transportation temperature.

Additional safety information:

- When installing and operating the relevant national regulations and safety rules must also be observed.

**In gas hazardous areas (explosive media) only the version VA 550 EX must be used.**

When using the Flow-/ Consumption sensors VA 550 Ex in gas hazardous areas the special requirements specified in the Ex documentation must be observed.

3.1 Intended Use

The instrument described in this manual is exclusively to use for measuring the thermal mass flow of gases. At the same time, the gas temperature is measured too.

The VA 550 can be configured for measuring a predetermined range of pure gases or of gas mixtures.

Consumption measurement of gases such as Air, oxygen, nitrogen, carbon dioxide, argon, etc. and with ATEX approval explosive gases such as natural gas, methane, propane and hydrogen.

Improper or incorrect use the operational reliability will be canceled. The manufacturer is not liable for any damage resulting by improper or incorrect use.

3.2 Installation and commissioning

- Installation, electrical installation, commissioning, operation and maintenance of the device must only be carried by qualified personnel, which were authorized by the plant operator. The personnel must read the operating instructions and understand and follow their instructions.
- If carrying out welding work on the pipeline the grounding of the welding unit is not allowed to be done over the VA 550 itself.
- The installer has to ensure that the VA 550 is connected according to the electrical connection diagrams properly. The sensor must be grounded, unless special protective measures have been taken (e.g. galvanically isolated power supply)
- The existing/ applicable national regulations governing opening and repair of the device have to be applied.
- When using the VA 550 (ATEX Version) hazardous areas, in addition with the standard manual a separate Ex documentation is enclosed. The installation instructions and connection values indicated in these must also be observed.
- The device fulfills the general safety requirements in accordance with EN 61010-1, the EMC requirements of IEC / EN 61326 and NAMUR recommendation NE 43.

4 Technical data

Measures:	mass flow, consumption flow speed, temperature
Measuring principle:	thermal mass flow sensor
Medium temperature range:	-40 ... 180°C Probe (ATEX-Version -20°C ... 120°C)
Operating temperature range:	-20 ... 70 °C
Operating pressure:	50 bar
Power supply:	18 ... 36 VDC Optional: PoE according to IEEE 802.3af, PD Class 2 (max. 6.5W), voltage from 36V to 57V DC
Power consumption:	max. 5W
Output:	Modbus RTU (acc. EIA/TIA-485 Standard) 2 x 4...20 mA active (optional passive) RL < 500Ohm galvanically isolated pulse (Pulse weight freely selectable, Alarm max. 48Vdc 0,5A, optional: Modbus TCP, HART, ProfibusDP, Profi Net,
Accuracy: Standard version* (m.v. of meas. value) (f.s. of full scale)	± 1,5 % m.v. ± 0,3 % f.s.
Accuracy: Precision version* (m.v. of meas. value) (f.s. of full scale)	± 1,0 % m.v. ± 0,3 % f.s.
Repeatability :	0,25% m.v in case of correct mounting(mounting aid, position, inlet section
Accuracy indications:	referred to ambient temperature 22°C +/-2°C, system pressure 6bar
Response time:	t90 < 3s
Display:	2" TFT Color Display (320 x 240)
Screw in thread:	G 1/2" ISO 228, NPT 1/2", R 1/2", PT 1/2"
Material:	Housing aluminum die cast, probe stainless steel1,4571
Protection class	IP67

* Reference conditions for Temperature and pressure can be freely set, standard conditions are 0 ° and 1013 mbar.

4.1 Signal circuits

4.1.1 Modbus

- According Standard EIA/TIA-485

4.1.2 Current output

4.1.2.1 Aktive

- Galvanically isolated
- 4 ... 20 mA
- $R_L < 500 \text{ Ohm}$

4.1.2.2 Passive

- Galvanically isolated
- 4 ... 20 mA
- $R_L < 500 \text{ Ohm}$
- $V_{in} 12\text{-}36\text{Vdc}$

4.1.3 Pulse

- Galvanically isolated (dry contact)
- Passive: 48Vdc , 500 mA
- Max. pulse output freq. 50Hz

4.1.4 Alarm

- Galvanically isolated
- Max. 48Vdc, 500mA

4.2 Measuring range flow VA 550

The flow-/consumption sensor VA 550 is available in 3 different versions:

- Standard max. measuring range of 92,7 m/s
- Max-Version max. measuring range of 185.0 m/s
- High speed-Version max. measuring range of 224 m/s

The sensors are programmed to pipe inner diameter of 53,1 mm this corresponds to analogue output 4- 20 mA of:

- Standard Version 0 ... 600 m³/h
- Max-Version 0 ... 1197,59 m³/h
- Highspeed-Version 0 ... 1450,06 m³/h

In case of use in other inner pipe diameter the diameter, using the display version, the diameter has to be set first.

For changing the inner pipe diameter and adjusting the 4...20mA scaling, please refer to chapter "Operation".

The corresponding scale values for the respective version could be found in sections 4.2.1 to 4.2.3.

Example:

Pipe 1", Inner diameter 25mm

- Standard Version 0 ... 122,2 m³/h
- Max-Version 0 ... 1197,59 m³/h
- Highspeed-Version 0 ... 1450,06 m³/h

4.2.1 Measuring range „Standard Version“

Innerdiameter of pipe		Standard Version (92,7 m/s)								Recommended Sensor lenght
		Full scale value in in Nm³/h								
Inch	mm	Air ²⁾	Air ³⁾	Ar ³⁾	CO2 ³⁾	N2 ³⁾	O2 ³⁾	N2O ³⁾	Methane ³⁾	
									Natural gas ³⁾	
1/2"	16,1	45,6	41,9	71,3	45,1	40,5	43,5	44,7	26,9	160 mm
3/4"	21,7	89,1	81,9	139,3	88,1	79,2	85,0	87,4	52,7	
1"	25,0	122,2	112,3	191,0	120,9	108,6	116,5	119,8	72,2	
	26,0	132,9	122,1	207,7	131,5	118,1	126,7	130,3	78,6	
	27,3	147,5	135,7	230,8	146,1	131,3	140,8	144,8	87,3	
	28,5	162,0	148,9	253,2	160,3	144,0	154,5	158,9	95,8	
	30,0	180,9	166,3	282,8	179,0	160,8	172,5	177,4	107,0	
1 1/4"	32,8	218,8	201,1	342,0	216,5	194,5	208,7	214,6	129,4	
	36,0	266,3	244,8	416,3	263,4	236,7	254,0	261,1	157,4	
	36,3	270,7	249,2	423,8	268,2	241,0	258,5	265,9	160,3	
1 1/2"	39,3	320,1	294,7	501,2	317,2	285,0	305,7	314,4	189,5	
	40,0	332,5	305,7	519,8	329,0	295,6	317,1	326,1	196,6	
	41,9	366,7	335,5	570,5	361,1	324,4	348,1	357,9	215,8	
	43,1	389,4	358,0	608,8	385,3	346,2	371,4	381,9	230,3	
	45,8	441,9	406,3	691,0	437,3	392,9	421,5	433,5	261,3	
2"	50,0	530,6	487,8	829,6	525,0	471,8	506,1	520,5	313,8	
	51,2	557,1	512,1	871,0	551,2	495,3	531,4	546,4	329,4	
	53,1	600,0	551,5	938,0	593,6	533,4	572,3	588,4	354,7	
	54,5	632,8	581,7	989,3	626,1	562,6	603,6	620,6	374,2	
	57,5	707,8	685,9	1166,6	738,3	663,4	711,7	731,8	441,2	
	60,0	773,6	711,1	1209,4	765,4	687,8	737,8	758,7	457,4	
	64,2	888,9	817,2	1389,7	879,5	790,3	847,8	871,8	525,6	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar

Innerdiameter of pipe		Standard Version (92,7 m/s)								Recommended Sensor lenght
		Full scale value in in Nm³/h								
Inch	mm	Air ²⁾	Air ³⁾	Ar ³⁾	CO2 ³⁾	N2 ³⁾	O2 ³⁾	N2O ³⁾	Methane ³⁾ Natural gas ³⁾	220 mm
2 1/2"	65,0	913,5	838,7	1426,3	902,6	811,1	870,2	894,8	539,4	
	70,3	1071	984,6	1674,5	1059,7	952,2	1021,6	1050,4	633,3	
	71,1	1095	1007,1	1712,8	1083,9	974,0	1044,9	1074,5	647,8	
	76,1	1258	1156,5	1966,9	1244,8	1118,5	1200,0	1233,9	743,9	
3"	80,0	1390	1279,6	2176,3	1377,3	1237,6	1327,7	1365,3	823,1	
	82,5	1480	1362,5	2317,2	1466,5	1317,7	1413,7	1453,7	876,4	
	84,9	1569	1442,9	2454,0	1553,0	1395,5	1497,1	1539,5	928,1	
	90,0	1766	1623,5	2761,0	1747,3	1570,1	1684,4	1732,1	1044,2	
4"	100,0	2183	2006,7	3412,8	2159,8	1940,7	2082,0	2140,9	1290,7	
	107,1	2507	2304,5	3919,3	2480,3	2228,8	2391,1	2458,7	1482,2	
	110,0	2644	2431,0	4134,4	2616,5	2351,1	2522,3	2593,6	1563,6	
5"	125,0	3423	3143,0	5345,2	3382,7	3039,7	3261,0	3353,2	2021,5	
	133,7	3921	3595,7	6115,2	3870,0	3477,5	3730,7	3836,2	2312,7	
6"	150,0	4941	4531,3	7706,4	4877,0	4382,4	4701,5	4834,4	2914,5	
	159,3	5579	5110,6	8691,6	5500,5	4942,6	5302,5	5452,5	3287,1	
	182,5	7323	6715,6	11421,2	7227,9	6494,9	6967,8	7164,9	4319,4	
	190,0	7947	7278,9	12379,2	7834,2	7039,7	7552,3	7765,8	4681,7	
8"	200,0	8816	8074,9	13733,0	8690,9	7809,5	8378,2	8615,1	5193,7	
	206,5	9398	8608,3	14640,1	9265,0	8325,4	8931,6	9184,2	5536,8	
10"	250,0	13742	12632,1	21483,4	13595,8	12216,9	13106,5	13477,2	8124,8	
	260,4	14945	13721,2	23335,8	14768,0	13270,3	14236,6	14639,2	8825,4	
12"	300,0	19836	18211,8	30972,9	19601,2	17613,3	18895,9	19430,2	11713,7	
	309,7	21139	19408,6	33008,2	20889,3	18770,7	20137,5	20707,0	12483,5	
	339,6	25418	23337,1	39689,5	25117,5	22570,1	24213,6	24898,4	15010,2	
	388,8	33317	32376,6	55063,0	34846,6	31312,6	33592,6	34542,6	20824,4	
	500,0	55101	50588,4	86036,0	54447,9	48925,9	52488,5	53972,9	32538,1	
	600,0	79345	72847,4	123891,8	78405,0	70453,3	75583,4	77720,9	46854,9	
	700,0	107998	99153,3	168630,5	106717,9	95894,8	102877,4	105786,8	63774,7	
	800,0	141058	129506,4	220252,1	139386,6	125250,3	134370,5	138170,6	83297,5	
	900,0	178527	163906,5	278756,5	176411,1	158519,9	170062,7	174872,1	105423,5	
	1000,0	220404	202353,8	344143,9	217791,5	195703,6	209953,9	215891,5	130152,4	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar

4.2.2 Measuring range „Max Version“

Innerdiameter of pipe		Max Version (185,0 m/s)								Recommended Sensor lenght
		Full scale value in in Nm³/h								
Inch	mm	Air ²⁾	Air ³⁾	Ar ³⁾	CO2 ³⁾	N2 ³⁾	O2 ³⁾	N2O ³⁾	Methane ³⁾ Natural gas ³⁾	160 mm
1/2"	16,1	90,98	83,7	142,2	90,0	80,9	86,7	89,2	53,8	
3/4"	21,7	177,84	163,5	278,0	176,0	158,1	169,6	174,4	105,2	
1"	25,0	243,88	224,2	381,2	241,4	216,9	232,5	239,1	144,2	
	26,0	265,20	243,8	414,6	262,5	235,8	252,9	260,0	156,8	
	27,3	294,72	271,0	460,7	291,7	262,1	281,0	289,0	174,3	
	28,5	323,32	297,3	505,4	320,0	287,5	308,3	317,0	191,2	
	30,0	361,08	332,0	564,5	357,4	321,1	344,3	354,1	213,5	
1 1/4"	32,8	436,69	401,5	682,7	432,2	388,3	416,4	428,2	258,2	
	36,0	531,48	488,7	830,8	526,0	472,6	506,8	521,1	314,3	
	36,3	541,06	497,5	845,8	535,5	481,1	515,9	530,5	320,0	
1 1/2"	39,3	639,84	588,3	1000,2	633,3	568,9	610,1	627,4	378,4	
	40,0	663,68	610,2	1037,5	656,9	590,1	632,8	650,8	392,5	
	41,9	728,41	669,7	1138,7	720,9	647,7	694,5	714,2	430,7	
	43,1	777,34	714,7	1215,2	769,4	691,2	741,2	762,2	459,7	
	45,8	882,17	811,1	1379,0	873,1	784,4	841,2	865,0	521,7	
2"	50,0	1059,23	973,9	1655,8	1048,3	941,9	1010,0	1038,6	626,4	
	51,2	1112,05	1022,5	1738,4	1100,6	988,8	1060,4	1090,4	657,6	
	53,1	1197,59	1101,1	1872,1	1185,3	1064,9	1141,9	1174,3	708,2	
	54,5	1263,13	1161,4	1974,6	1250,2	1123,2	1204,4	1238,5	747,0	
	57,5	1489,43	1369,5	2328,3	1474,1	1324,4	1420,2	1460,5	880,8	
	60,0	1544,12	1419,8	2413,8	1528,3	1373,0	1472,3	1514,1	913,1	
	64,2	1774,33	1631,4	2773,7	1756,1	1577,7	1691,8	1739,8	1049,3	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar

Innerradius of pipe		Max Version (185,0 m/s)								Recommended Sensor lenght
		Full scale value in in Nm³/h								
Inch	mm	Air ²⁾	Air ³⁾	Ar ³⁾	CO2 ³⁾	N2 ³⁾	O2 ³⁾	N2O ³⁾	Methane ³⁾	
									Natural gas ³⁾	
2 1/2"	65,0	1821,03	1674,4	2846,7	1802,3	1619,2	1736,4	1785,6	1076,9	220 mm
	70,3	2137,86	1965,7	3342,0	2115,9	1901,0	2038,5	2096,3	1264,2	
	71,1	2186,80	2010,7	3418,5	2164,3	1944,5	2085,1	2144,2	1293,2	
	76,1	2511,24	2309,0	3925,7	2485,4	2233,0	2394,5	2462,4	1485,0	
3"	80,0	2778,58	2554,8	4343,6	2750,0	2470,7	2649,4	2724,5	1643,1	
	82,5	2958,51	2720,2	4624,9	2928,1	2630,7	2821,0	2900,9	1749,5	
	84,9	3133,15	2880,8	4897,9	3101,0	2786,0	2987,5	3072,2	1852,8	
	90,0	3525,11	3241,2	5510,6	3488,9	3134,5	3361,2	3456,5	2084,6	
4"	100,0	4357,22	4006,3	6811,4	4312,5	3874,4	4154,7	4272,4	2576,6	
	107,1	5003,91	4600,9	7822,3	4952,5	4449,4	4771,3	4906,5	2959,1	
	110,0	5278,56	4853,4	8251,7	5224,3	4693,6	5033,2	5175,8	3121,5	
5"	125,0	6824,50	6274,8	10668,3	6754,4	6068,3	6507,2	6691,7	4035,7	300 mm
	133,7	7807,53	7178,7	12205,1	7727,3	6942,4	7444,6	7655,6	4617,0	
6"	150,0	9839,04	9046,6	15380,8	9738,0	8748,8	9381,7	9647,6	5818,3	
	159,3	11096,91	10203,2	17347,2	10982,9	9867,2	10581,1	10881,0	6562,2	
	182,5	14581,94	13407,5	22795,1	14432,2	12966,1	13904,1	14298,2	8623,0	
	190,0	15805,08	14532,1	24707,2	15642,8	14053,7	15070,4	15497,5	9346,4	
8"	200,0	17533,48	16121,3	27409,1	17353,4	15590,6	16718,4	17192,3	10368,4	
	206,5	18691,68	17186,2	29219,6	18499,7	16620,4	17822,8	18327,9	11053,3	
10"	250,0	27428,75	25219,6	42877,8	27147,1	24389,4	26153,7	26895,0	16220,0	
	260,4	29793,76	27394,2	46574,9	29487,8	26492,3	28408,8	29214,0	17618,6	
12"	300,0	39544,48	36359,5	61817,6	39138,4	35162,5	37706,2	38775,0	23384,7	
	309,7	42143,03	38748,8	65879,8	41710,2	37473,1	40184,0	41323,0	24921,3	
	339,6	50673,25	46592,0	79214,6	50152,8	45058,1	48317,6	49687,2	29965,7	
	388,8	70301,30	64639,2	109898,0	69579,3	62511,2	67033,2	68933,3	41572,8	
	500,0	109845,79	100998,7	171715,7	108717,6	97673,7	104739,4	107708,2	64957,5	
	600,0	158177,93	145438,2	247270,6	156553,4	140650,1	150824,8	155099,9	93538,7	
	700,0	215297,74	197957,5	336562,7	213086,6	191440,4	205289,3	211108,2	127316,6	
	800,0	281205,22	258556,8	439592,2	278317,2	250044,6	268133,0	275733,1	166291,1	
	900,0	355900,35	327235,9	556358,8	352245,2	316462,7	339355,8	348974,7	210462,2	
	1000,0	439383,15	403995,0	686862,7	434870,6	390694,7	418957,8	430833,0	259829,8	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar

4.2.3 Measuring range „High Speed Version“

Innerradius of pipe		High Speed Version (224,0 m/s)								Recommended Sensor lenght
		Full scale value in in Nm³/h								
Inch	mm	Air ²⁾	Air ³⁾	Ar ³⁾	CO2 ³⁾	N2 ³⁾	O2 ³⁾	N2O ³⁾	Methane ³⁾	
									Natural gas ³⁾	
1/2"	16,1	110,16	101,3	172,2	109,0	98,0	105,0	108,0	65,2	160 mm
3/4"	21,7	215,33	198,0	336,6	213,0	191,5	205,3	211,2	127,4	
1"	25,0	295,30	271,6	461,7	292,1	262,6	281,6	289,6	174,7	
	26,0	321,11	295,3	502,0	317,7	285,6	306,2	314,9	189,9	
	27,3	356,85	328,2	557,9	353,0	317,3	340,3	350,0	211,1	
	28,5	391,48	360,0	612,0	387,3	348,1	373,3	384,0	231,6	
	30,0	437,20	402,1	683,5	432,5	388,8	416,9	428,8	258,6	
1 1/4"	32,8	528,75	486,3	826,6	523,1	470,2	504,2	518,6	312,8	
	36,0	643,52	591,8	1006,1	636,6	572,3	613,6	631,2	380,7	
	36,3	655,12	602,5	1024,2	648,1	582,6	624,7	642,5	387,5	
1 1/2"	39,3	774,73	712,5	1211,2	766,4	689,0	738,8	759,9	458,3	
	40,0	803,59	739,0	1256,3	795,0	714,6	766,3	788,2	475,3	
	41,9	881,96	811,1	1378,9	872,5	784,3	841,0	865,0	521,7	
	43,1	941,21	865,6	1471,5	931,1	837,0	897,5	923,1	556,7	
	45,8	1068,14	982,3	1669,9	1056,7	949,9	1018,5	1047,6	631,8	
2"	50,0	1282,52	1179,5	2005,1	1268,8	1140,5	1223,0	1257,9	758,6	
	51,2	1346,48	1238,3	2105,1	1332,1	1197,4	1284,0	1320,6	796,5	
	53,1	1450,06	1333,5	2267,0	1434,5	1289,5	1382,7	1422,2	857,7	
	54,5	1529,41	1406,5	2391,1	1513,0	1360,1	1458,4	1500,1	904,7	
	57,5	1803,42	1658,5	2819,5	1784,1	1603,8	1719,7	1768,8	1066,8	
	60,0	1869,63	1719,4	2923,0	1849,6	1662,6	1782,8	1833,7	1105,9	
	64,2	2148,38	1975,7	3358,8	2125,4	1910,5	2048,6	2107,1	1270,8	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar



Innerradius of pipe		High Speed Version (224,0 m/s)								Recommended
		Full scale value in in Nm³/h								Sensor lenght
Inch	mm	Air ²)	Air ³)	Ar³)	CO2³)	N2³)	O2³)	N2O³)	Methane³)	
									Natural gas³)	
2 1/2"	65,0	2204,93	2027,7	3447,2	2181,3	1960,8	2102,6	2162,6	1304,3	220 mm
	70,3	2588,55	2380,5	4046,9	2560,8	2302,0	2468,4	2538,9	1531,2	
	71,1	2647,80	2435,0	4139,6	2619,4	2354,7	2524,9	2597,0	1566,2	
	76,1	3040,63	2796,3	4753,7	3008,1	2704,0	2899,5	2982,3	1798,6	
3"	80,0	3364,33	3094,0	5259,8	3328,3	2991,8	3208,1	3299,7	1990,1	
	82,5	3582,20	3294,3	5600,4	3543,8	3185,6	3415,9	3513,4	2118,9	
	84,9	3793,65	3488,8	5931,0	3753,0	3373,6	3617,5	3720,8	2244,0	
	90,0	4268,24	3925,3	6672,9	4222,5	3795,7	4070,1	4186,3	2524,7	
4"	100,0	5275,76	4851,8	8248,1	5219,2	4691,7	5030,8	5174,5	3120,7	
	107,1	6058,78	5571,9	9472,3	5993,9	5388,0	5777,5	5942,5	3583,9	
	110,0	6391,34	5877,7	9992,2	6322,9	5683,7	6094,6	6268,6	3780,6	
5"	125,0	8263,17	7599,2	12918,6	8174,6	7348,3	7879,5	8104,6	4887,8	300 mm
	133,7	9453,44	8693,8	14779,4	9352,1	8406,8	9014,5	9272,0	5591,9	
6"	150,0	11913,22	10955,9	18625,0	11785,6	10594,3	11360,1	11684,5	7046,9	
	159,3	13436,25	12356,6	21006,1	13292,3	11948,7	12812,4	13178,3	7947,8	
	182,5	17655,97	16237,2	27603,2	17466,8	15701,2	16836,2	17317,0	10443,8	
	190,0	19136,96	17599,2	29918,6	18931,9	17018,2	18248,5	18769,6	11319,9	
8"	200,0	21229,73	19523,8	33190,4	21002,3	18879,3	20244,1	20822,2	12557,8	
	206,5	22632,08	20813,4	35382,8	22389,6	20126,4	21581,3	22197,6	13387,3	
10"	250,0	33211,03	30542,3	51921,9	32855,2	29534,1	31669,1	32573,5	19644,9	
	260,4	36074,61	33175,8	56398,8	35688,1	32080,6	34399,7	35382,1	21338,8	
12"	300,0	47880,89	44033,3	74856,6	47367,9	42579,8	45657,8	46961,7	28322,4	
	309,7	51027,24	46926,8	79775,6	50480,5	45377,8	48658,1	50047,7	30183,5	
	339,6	61355,72	56425,3	95923,1	60698,3	54562,8	58507,1	60177,9	36293,0	
	388,8	85121,58	78281,5	133078,5	84209,6	75697,4	81169,5	83487,5	50350,9	
	500,0	133002,47	122314,8	207935,1	131577,4	118277,2	126827,4	130449,3	78673,3	
	600,0	191523,55	176133,3	299426,6	189471,5	170319,2	182631,4	187847,0	113289,6	
	700,0	260684,83	239736,9	407552,8	257891,8	231823,3	248581,6	255680,6	154199,7	
	800,0	340486,31	313125,8	532313,9	336838,2	302789,6	324678,0	333950,2	201403,7	
	900,0	430927,99	396299,8	673709,7	426310,9	383218,1	410920,6	422655,7	254901,6	
	1000,0	532009,87	489259,1	831740,4	526309,8	473108,8	507309,4	521797,2	314693,3	

²⁾ Referred to DIN 1945 / ISO 1217 (20°C, 1000mbar) and compressed air.

³⁾ Referred to DIN 1343: 0°C, 1013,25 mbar

5 Dimensions

5.1 Dimension VA 550



Sensor lenght	L [mm]	H [mm]
C1	220	441
C2	300	521
C3	400	621
C4	500	721
C5	600	821
C7	160	381

6 Installation

6.1 Pipe/tube requirements


- Correctly sized gaskets
- Correct aligned flanges and gaskets
- Diameter mismatch at the pipe junctions should be avoided but must be less than 1mm. For further information see ISO 14511
- Ensure clean pipes after installation

6.2 Inlet / outlet runs

The principle of thermal Mass flow measurement is very sensitive against disturbances. Therefore, it is necessary to ensure the recommended inlet and outlet runs.

Table Inlet / Outlet runs

Flow obstruction before the measurement section	Min length Inlet run (L1)	Min length Outlet run (L2)
Slight curve (elbow < 90°)	12 x D	5 x D
Reduction (Pipe narrows to the measurement section)	15 x D	5 x D
Expansion (Pipe expands to the measurement section)	15 x D	5 x D
90° elbow or T-piece	15 x D	5 x D
2x elbow á 90° in einer Ebene	20 x D	5 x D
2x elbow á 90° 3-dimensional	35 x D	5 x D
Control valve	45 x D	5 x D



The values represent the min. lengths. In case the min. inlet / outlet runs could not be ensured, it must be expected to get increased or significant deviations of the measurement values.

6.3 Installation VA 550

The installation of the sensor is done via a ball valve $\frac{1}{2}$ ".

If no valid measuring point with a ball valve $\frac{1}{2}$ " is available there are following ways to set up a measuring point.



When using the consumption sensor in systems with working pressure > 10 bar, for safety reasons the use of a high pressure protection is required.

6.3.1 $\frac{1}{2}$ " welded nipple with ball valve $\frac{1}{2}$ "



Important:

Ensure that the system is in shut down, i.e. depressurized.

Note for installation with ball valve

Ball valve R $\frac{1}{2}$ " , DN 15

Passage ball valve: Minimum $\varnothing 15$ mm

6.3.2 Spot drilling collar with ball valve



In case the system could not be shut down, means to be set depressurized, there could be used the CS spot drilling collar (Order-No. 0530 1108) and drilling jig (Order-No. 0530 1108) to drill through the ball valve.

6.4 Installation of the Sensor

6.4.1 Mounting VA 550 onto the ball valve


- Assembly is carried out by inserting the connection thread with gasket. (G1/2" thread, SW 32) into the connection piece (ball valve). The sensor has to be tightened by hand as far as possible and then tightened with stipulated torque of 25-30 Nm. It must be ensured that the installation is pressure-tight.



- The sensor is then inserted to the required immersion depth and aligned according to the direction of the airflow. A depth scale engraved on the probe tube, a flow alignment arrow and an aligning device will be of help for you. Once the sensor has been aligned the adapter sleeve must be tightened with stipulated torque of 20-30Nm (SW 17).

Attention: Alignment of the sensor must not be modified when tightening the connection thread and adapter sleeve. In this case, please check the immersion depth and alignment again and correct it if necessary. The angular deviation should not be greater than $\pm 2^\circ$ in relation to ideal position as otherwise the measuring accuracy will decrease.

Calculation mounting depth:





Alignment



6.5 Alignment Display (Housing)

The sensor housing VA 550 can be turned in both directions, max. 345 °. For this purpose, the housing-connecting nut must be opened. The housing can be rotated to the desired position, a bigger rotation angle is prevented by internal stop pins.

After that, the housing-connecting nut is firmly retighten



The housing-connecting nut must not be completely unscrewed / opened, please only open it for one or two turns.

6.6 Tightening torques

To secure and guarantee the function and tightness following tightening torques have to be applied, see table 1.

Table 1

Pos	Description	Tightening torque [Nm]
20	VA 550 Cover with glass	3
30	VA 550 Cover closed	3
50	Grub screw with hexagon socket M4x6 DIN 914 A2	2
130	VA 550 Nut	15
150	Cylinder head screw DIN 6912 - M5x10 A2-70	4
240	V-MS-Ex-d 1 875 2000 50 2 03	8
250	RN16M20KNP	8

7 Connection diagram


7.1 Cable glands - clamping ranges

For ensuring the tightness and strain relief, connector cables with the following diameters must be used.


VA550 Standard clamping range : Ø 5- 9mm

VA550 Ex clamping range : Ø5-10mm


7.2 Connector pin assignment



Standard version with 1x analogue output (not galvanically isolated)



Version with option board 2x analogue outputs galvanically isolated



Version with option board MBUS

Connector	Pin	Signal Description
X1 Power supply	1	VB - (GND)
	2	VB+ (12V – 36 Vdc)
X2 Modbus	1	Modbus (B)
	2	Modbus shield
	3	Modbus (A)
X3 current output	1	I- Active
	2	I+ Active
X4 Analogue output	1	Pulse / Alarm *
	2	Pulse / Alarm *
	3	Direction input
	4	GND
X5 Current output 1	1	I- Active**
	2	I+ Active **
X6 Current output 2	1	I- Active **
	2	I+ Active **
K1 Mbus	1	Mbus
	2	Mbus

* Outputs are galvanically isolated.


** The Current outputs, X5 and X6, are optional.(Active and passive version available).

7.3 Wire connection

7.3.1 General:

- Wiring to be done in strainless state only.
- Length of cable skinning to be minimized
- Not used cable entries must be closed with end caps
- Use of cables with cross section of $\geq 0.25\text{mm}^2$


7.3.2 Power supply



7.3.3 Modbus RTU:

If the sensor placed at the end of the Modbus system a termination is required.

Therefore, the enclosed 120R resistor is to be connected at Pin 1 and Pin 3 of connector „X2“




7.3.4 Modbus TCP (Ethernet) Optional PoE

M12 x-coded

Data LINES: 1,2 und 3,4


PoE LINES: 5,6 und 7,8



Connection cable: Cat 6.

*PoE: Power over Ethernet


7.3.5 Pulse Output



8 Operation VA 550

Remark: In version with display only

The operation of the VA 550 are carried out by 2 optical keys through the glass cover. Thus, the VA 550 can be operated from the outside without opening the cap.



Selection of the individual menu items is done by pressing the ">" and confirm by pressing "OK".

Inputs or changes can be made with all white deposit fields, selected field will be highlighted with yellow background.

Words in **green font** refer mainly to the pictures in the section of the chapter, but also on important menu paths or menu items that are related to are in **green font**.

The menu navigation is generally in a **green font**!

The table of contents and chapter references in **blue font** contain links to the respective chapter title.


8.1 Main menu (Home)

8.1.1 Initialization




After switching on the VA 550 the initialized screen is displayed followed by the main menu.

8.2 Main menu



Switching to pages 2-4 or back by pressing key „>“



AV-Time (Period for average value calculation) could be changed under [Sensor Setup.-Advanced– AV-Time](#)

8.3 Settings


The settings menu could accessed by pressing the key „OK“.

But the access to the *settings menu* is password protected.



Factory settings for password at the time of delivery: 0000 (4 times zero).


If required the password could be changed at *Setup–User setup-Password*.



Selection of a menu item or to change a value is done with the key „>“, a final move to the chosen menu item or takeover of the value change needs the confirmation by pressing the key „OK“

8.3.1 Sensor Setup


Setup → Sensor Setup



For changes, first select the menu item with key „>“ and then confirm it with **“OK”**.

8.3.1.1 Input / change tube diameter

Settings → Sensor Setup → Diameter



In order to change, e.g. the unit, first select by pressing key „>“ the field **“Units”** and then key **“OK”**.



Select with the key „>“ the correct unit and then confirm selection by pressing 2x **„OK”**.

Entering / changing the diameter via button „>“, select the respective position and activate the position with the **“OK”** button.

By pressing „>“ the position value is incremented by 1. Complete with **“OK”** and activate next number position. Confirming entry by pressing **„OK”**.

8.3.1.2 Input / change consumption counter

Setup → Sensor Setup → Total Counter → Unit button



In order to change, e.g. the unit, first select by pressing key „>“ the button **“Unit”** and then key **“OK”**.

Select with the key „>“ the correct unit and then confirm selection by pressing 2x **„OK”**.

Entering / changing the consumption counter via button „>“, select the respective position and activate the position with the **“OK”** button.

By pressing „>“ the position value is incremented by 1. Complete with **“OK”** and activate next number position.


Confirm entry by pressing **„OK”**.

Important!

When the counter reach 100000000 m³ the counter will be reset to zero.

8.3.1.3 Definition of the units for flow, velocity, temperature and pressure

Setup → Sensor Setup → Units







To make changes to the unit for the respective measurement value, first select by pressing „>“ the field of the „measurement value“ and activate „it with **„OK”** .

Selection of the new unit with „>“

In case the quantity of units selectable are not presentable on one page, pleas move to next page by pressing **„<<”** .

Confirm selection by pressing 2x **„OK”**.

Procedure for all 4 measurement-variables is analogous.




8.3.1.4 Definition of the reference conditions

Here can be defined the desired measured media reference conditions for pressure and temperature and times for the filter and averaging.

- Factory pre-setting for reference temperature and reference pressure are 20 °C, 1000 hPa
- All volume flow values (m³/h) and consumption values indicated in the display are related to 20 °C and 1000 hPa (according to ISO 1217 intake condition)
- Alternatively 0 °C and 1013 hPa (=standard cubic meter) can also be entered as a reference.
- **Do not enter the operation pressure or the operation temperature under reference conditions!**

Setup → Sensor Setup → Advanced



To make changes, first select a menu with button „>“ and confirm selection by pressing „OK“.

Setup → Sensor Setup → Advanced → Ref.Pref




In order to change, e.g. the unit, first select by pressing key „>“ the field „Units“ and then key „OK“.

Select with the key „>“ the correct unit and then confirm selection by pressing 2x „OK“.

Input / change of the value by selecting the respective position with button „>“ and entering by pressing button „OK“.


Setup → Sensor Setup → Advanced → Ref.Temp



By pressing „>“ the position value is incremented by 1. Complete with „OK“ and activate next number position.

Procedure for changing the reference temperature is the same.


Setup → Sensor Setup → Advanced → *Filtertime*



The screenshot shows a menu titled "Filtertime" with a blue header. Below the header, there are four input fields containing the digits "2", "0", "0", and "0". At the bottom left is a button labeled "CLR", and at the bottom right is a button labeled "back".

Under item "*Filtertime*" an attenuation can be defined.
Input values of 0 -10000 in [ms] are possible

Setup → Sensor Setup → Advanced → *AV-Time*




The screenshot shows a menu titled "AV-Time" with a blue header. Below the header, there are four input fields containing the digits "1", "4", "4", and "0". At the bottom left is a button labeled "CLR", in the center is a button labeled "OK", and at the bottom right is a button labeled "Cancel".

The time period for averaging can be entered here.
Input values of -1440 1 [minutes] are possible.
For average values, see display window 3 + 4


8.3.1.5 Setting of Zeropoint and Low-flow cut off

Setup → Sensor Setup → ZP Adjust



To make changes, first select a menu with button „>“ and confirm selection by pressing „OK“.

Setup → Sensor Setup → ZP Adjust → ZeroPnt




When, without flow, the installed sensor shows already a flow value of > 0 m³/h herewith the zero point of the characteristic could be reset.

For an input / change of the value select with the button „>“ the respective number position and activate it with „OK“.

By pressing „>“ the position value is incremented by 1. Confirm the input with „OK“ and activate next number position.

Leave menu with button „Back“

Setup → Sensor Setup → ZP Adjust → CutOff




With the low-flow cut off activated, the flow below the defined "LowFlow Cut off" value will be displayed as 0 m³/h and not added to the consumption counter.

For an input / change of the value select with the button „>“ the respective number position and activate it with „OK“.

By pressing „>“ the position value is incremented by 1. Confirm the input with „OK“ and activate next number position.

Leave menu with button „Back“

Setup → Sensor Setup → ZP Adjust t → Reset



By selection of „Reset“ all settings for „ZeroPnt“ and „CutOff“ are reset.

Menu item to be select with button „>“ and confirm the reset with „OK“.

Leave menu with button „Back“

8.3.2 Modbus RTU




8.3.2.1 Setup

The Flow sensors VA 550 comes with a Modbus RTU Interface.
Before commissioning the sensor the communication parameters

- Modbus ID, Baud rate, Parity und Stop bit

must be set in order to ensure the communication with the Modbus master.

Settings → Modbus Setup

For changes, e.g. the sensor ID, first select by pressing key „>“ the field **“ID”** and then key **“OK”**.

Select the desired position by pressing the **“>”** and select with **“OK”** button.

Change values by pressing the **“>”** values takeover by pressing **“OK”**.

Inputs for baudrate, stopbit and parity is done analogue.

By means of the button "Byte Order" it is possible to change the data format (Word Order). Possible formats are "ABCD" (Little Endian) and "CDAB" (Middle Endian)

Saving the changes by pressing **“Save”**, therefore select it with key **“>”** and then confirm it with **“OK”**.

Reset to the default settings by activating **“Set to Default”**-

Default values out of factory:

Modbus ID:	1
Baud rate:	19200
Stopbit:	1
Parity:	even
Byte Order:	ABCD

Remark: If the sensor placed at the end of the Modbus system, a termination is required.

Therefore, the enclosed 120R resistor is to be connected at Pin 1 and Pin 3 of connector „X2“

8.3.3 Modbus TCP (Optional)

8.3.3.1 Setup

The Flow sensors VA 550 comes optional with a Modbus TCP Interface (HW Interface:M12 x 1 X-coded connector).

Device supports with this option the Modbus TCP protocol for communication with SCADA systems. TCP port is set to 502 by default. Port can be changed at the sensor or using PC Service Software

Modbus device address (Unit Identifier) can be set in the range of 1- 255.


Specification and description of the Modbus protocol is free to download on: www.modbus.org.

Supported Modbus commands (functions):

Command	Code	Description
Function Code	3	(Read holding register)
Function code	16	(Write multiple registers)


For more details, please see **VA 5xx Modbus RTU_TCP Installation V1.04**

Settings → Network Setup



8.3.3.1.1 Network Setup DHCP

Settings → Network Setup Settings → IP Address



Here you can set up and made a connection, with or without **DHCP**, to a computer.

Remark:

With activated **DHCP** the automatic integration of the sensor in an existing network is possible, without a manual configuration.


Storing of settings by pressing "**Save**"

8.3.3.1.2 Network Settings static IP

Settings → Network Setup Settings → IP Address → IP Address

Settings → Network Setup Settings → IP Address → Sub Netz

Settings → Network Setup Settings → IP Address → Gateway



*** IP Address Setup ***


DHCP ☐

IP Address 192.168.172.010

Subnet 255.255.255.000

Gateway 192.168.172.001

Advanced back



*** IP Address Setup ***

DHCP ☐

IP Address 192.168.172.010

Subnet 255.255.255.000

Gateway 192.168.172.001

Advanced back



IP Setup

1 9 2

CLR back

For manual (static) IP, the **"IP Address"**, **"Subnet"** and **"Gateway"** selection keys must be selected and activated with **"OK"**.

The first data field of the selection, in this case the IP address, is then marked (red).


Confirm with **"OK"** the corresponding input menu is opened.

By means of **">"**, the next data field is changed.

Select the desired position with the **">"** key and activate it with the **"OK"** key.

Change the values with the **">"** key, and accept the values with the **"OK"** key.


Procedure for **"Subnet"** and **"Gateway"** is analogous.



Subnet Setup

2 5 5


CLR back



Gateway Setup

1 9 2

CLR back



*** IP Address Setup ***

DHCP ☐

IP Address 192.168.172.011

Subnet 255.255.255.000


Gateway 192.168.172.001

Advanced Save Cancel

Store the settings by **„Save“**

8.3.3.1.3 Modbus TCP Settings

Settings → Network Setup Settings → IP Address → MB TCP




*** MB TCP ***

ID	5
Port	502
Byte Order	ABCD

Set to Default back

Settings → Network Setup Settings → IP Address → ID

Settings → Network Setup Settings → IP Address → Port



Modbus TCP UI

5

CLR back

Modbus TCP Port

5 0 2

CLR zurück

For changes, e.g. the sensor ID, first select by pressing key „>“ the field **“ID”** and then key **“OK”**.

Select the desired position by pressing the **“>”** and select with **“OK”** button.

Change values by pressing the **“>”** values takeover by pressing **“OK”**.

Input for the port is done analogue.

By means of the button **“Byte Format”** it is possible to change the data format (Word Order). Possible formats are **“ABCD”** (Little Endian) and **“CDAB”** (Middle Endian)

Saving the changes by pressing **“Save”**, therefore select it with key **“>”** and then confirm it with **“OK”**.

Reset to the default settings by activating **“Set to Default”**-

8.3.3.2 Modbus Settings (2001...2005)

Modbus Register	Register Address	No. of Byte	Data Type	Description	Default Setting	Read Write	Unit /Comment
2001	2000	2	UInt16	Modbus ID	1	R/W	Modbus ID 1...247
2002	2001	2	UInt16	Baudrate	4	R/W	0 = 1200 1 = 2400 2 = 4800 3 = 9600 4 = 19200 5 = 38400
2003	2002	2	UInt16	Parity	1	R/W	0 = none 1 = even 2 = odd
2004	2003	2	UInt16	Number of Stopbits		R/W	0 = 1 Stop Bit 1 = 2 Stop Bit
2005	2004	2	UInt16	Word Order	0xABCD	R/W	0xABCD = Big Endian 0xCDAB = Middle Endian

8.3.3.3 Values Register (1001 ...1500)

Modbus Register	Register Address	No. of Byte	Data Type	Description	Default	Read Write	Unit /Comment
1101	1100	4	Float	Flow in m³/h		R	
1109	1108	4	Float	Flow in Nm³/h		R	
1117	1116	4	Float	Flow in m³/min		R	
1125	1124	4	Float	Flow in Nm³/min		R	
1133	1132	4	Float	Flow in ltr/h		R	
1141	1140	4	Float	Flow in Nltr/h		R	
1149	1148	4	Float	Flow in ltr/min		R	
1157	1156	4	Float	Flow in Nltr/min		R	
1165	1164	4	Float	Flow in ltr/s		R	
1173	1172	4	Float	Flow in Nltr/s		R	
1181	1180	4	Float	Flow in cfm		R	
1189	1188	4	Float	Flow in Ncfm		R	
1197	1196	4	Float	Flow in kg/h		R	
1205	1204	4	Float	Flow in kg/min		R	
1213	1212	4	Float	Flow in kg/s		R	
1221	1220	4	Float	Flow in kW		R	

Operation

Modbus Register	Register Address	No. of Byte	Data Type	Description	Default	Read Write	Unit /Comment
1269	1268	4	UInt32	Consumption m ³ before comma	x	R	
1275	1274	4	UInt32	Consumption Nm ³ before comma	x	R	
1281	1280	4	UInt32	Consumption ltr before comma	x	R	
1287	1286	4	UInt32	Consumption Nltr before comma	x	R	
1293	1292	4	UInt32	Consumption cf before comma	x	R	
1299	1298	4	UInt32	Consumption Ncf before comma	x	R	
1305	1304	4	UInt32	Consumption kg before comma	x	R	
1311	1310	4	UInt32	Consumption kWh before comma	x	R	
1347	1346	4	Float	Velocity m/s			
1355	1354	4	Float	Velocity Nm/s			
1363	1362	4	Float	Velocity Ft/min			
1371	1370	4	Float	Velocity NFt/min			
1419	1418	4	Float	GasTemp °C			
1427	1426	4	Float	GasTemp °F			

Remark:

- **For DS400 / DS 500 / Handheld devices - Modbus Sensor Datatype**
„Data Type R4-32“ match with „Data Type Float“
- For more additional Modbus values please refer to VA5xx_Modbus_RTU_TCP Installation_1.04_EN.doc

8.3.4 Pulse / Alarm

Setup → Sensor Setup → Pulse/ Alarm

Relay Mode:	Alarm
Unit:	°C
Value:	20.0
Hyst.:	5.0
Hi-Lim.:	OK Cancel

*** Pulse / Alarm ***	
Relay Mode:	Alarm
Unit:	°C
Value:	20.0
Hyst.:	5.0
Hi-Lim.:	OK Cancel


*** Pulse / Alarm ***	
Relay Mode:	Pulse
Unit:	m³
Value:	0.1
Polarity:	pos.
Pls per second at max Speed: 0 Back	

The galvanically isolated output can be defined as pulse- or alarm output.
Selection of field „**Relay Mode**“ with key „>“ and change modulus by pressing key „OK“.

For alarm output following units could be chosen: kg/min, cfm, ltr/s, m³/h, m/s, °F, °C and kg/s.
„**Value**“ defines the Alarm value, „**Hyst.**“ defines the desired hysteresis and with „**Hi-Lim**“ or „**Lo-Lim**“ the alarm settings when the alarm is activated
Hi-Lim: Value over limit
Lo-Lim: Value under limit

For the pulse output following units could be chosen: kg, cf, ltr and m³. The pulse value definition to be done in menu „**Value**“ . Lowest value is depending on max. flow of sensor and the max frequency of pulse output of 50Hz.

With „**Polarity**“ the switching state could be defined. Pos. = 0 → 1 neg. 1 → 0



8.3.4.1 Pulse output

The maximum frequency for pulse output is 50 pulses per second (50Hz).
The Pulse output is delayed by 1 second.

Pulse value	[m³ /h]	[m³ /min]	[l/min]
0.1 ltr / Pulse	1,8	0,3	300
1ltr / Pulse	18	3	3000
0.1m³ / Pulse	18000	300	300000
1 m³ / Pulse	180000	3000	3000000


Table 1 Maximum flow for pulse output

Entering pulse values that are not allow a presentation to the full scale value, are not allowed. Entries are discarded and error message displayed.

8.3.5 User Setup

8.3.5.1 Password

Settings → UserSetup → Password



To make changes, first select a menu with button „>“ and confirm selection by pressing „OK“.

It is possible to define a password. The required password length is 4 digits. Please select with button „>“ a figure and confirm it with „OK“. Repeat this 4 times.


With „<“ the last figure could be deleted. Password input have to be inserted twice.

Confirmation of input/password by pressing „OK“.

Factory settings for password at the time of delivery: 0000 (4 times zero).

8.3.5.2 Language

Settings → UserSetup → Language





Currently 4 languages have been implemented and could be selected with button „>“.

Change of language by confirming with “OK”. Leaving the menu with button “back”.

8.3.5.3 Display / Touch

Settings → UserSetup → Display / Touch



With the button „-“ and with button „+“ it is possible to adjust the backlight / display brightness. The actual / adjusted backlight brightness is shown in the graph „**Backlight.**“

By activation „**Dimming after**“ and entering a time a display dimming could be set.


With „**Rotate Screen**“ the display information could be rotated by 180°.

By activation of „**Key Lock**“ the operation of the sensor locked.

Unlocking the keyboard is only possible by restarting the sensor and calling the operating menu within the first 10s. To do this, use the „**OK**“ button to enter the operating menu during this period

8.3.6 Advanced


Settings → Advanced



By pressing „**Factory Reset**“ the sensor is set back to the factory settings.


8.3.7 4 -20mA

Settings → 4-20mA



To make changes, first select a menu with button „>“ and confirm selection by pressing „OK“.


Settings → 4-20mA → Channel 1



The 4-20 mA Analogue output of the Sensor VA 550 can be individually adjusted.


It is possible to assign following values „Temperature“, „Velocity“ und „Flow“ to the channel CH 1.

To make changes, first select the value item with button „>“ and confirm
Moving between the different measurements values or to deactivate the 4-20mA with setting to „unused“ by pressing „OK“.



To the selected measurement value a corresponding / appropriate unit needs to be defined. Select „Unit“ with „>“ and open menu with „OK“. Select required unit with „>“ and take over by pressing „OK“.




Here e.g. for the measurement value Flow, procedure for the other measurements values is analog.



For saving the changes done press button „Save“ to discard the changes press button „Cancel“.

Leaving the menu with „Back“.

Settings → 4-20mA → Channel 1 → AutoRange

The scaling of the 4-20mA channel can be done automatically "Auto Range = on" or manual "AutoRange = off" .

With button „>“ select the menu item „AutoRange“ select with „OK“ the desired scaling method. (Automatically or manually)

In case of **AutoRange = off** with „Scale 4mA“ and „Scale 20mA“ the scale ranges needs to be defined.

Select with button „>“ the item „Scale 4mA“ or „Scale 20mA“ and confirm with „OK“ .


Input of the scaling values will be analogous as described before for value settings.

Using „CLR“ clears up the complete settings at once.

For „Auto on“ , the max. scaling is calculated based on the inner tube diameter, max. measurement range and the reference conditions settings.

Take over of the inputs with „Save“ and leaving the menu with „Back“ .

Settings → 4-20mA → Error Current



This determines what is output in case of an error at the analog output.

- 2 mA Sensor error / System error
- 22 mA Sensor error / System error
- None Output according Namur (3.8mA – 20.5 mA)
< 4mA to 3.8 mA Measuring range under range
>20mA to 20.5 mA Measuring range exceeding

To make changes first select a menu item "Current Error" with button „>“ and then select by pressing the „OK“ the desired mode

For saving the changes done press button „Save“ to discard the changes press button „Cancel“.

Leaving the menu with „Back“.

Remark: Default setting VA 550 for analogue output is

Default settings for VA550 with option board analogue output

For max. speed see label on Sensor.

Channel 1:0...max. speed [m/s]

Channel 1:0...max. speed [m/s]

Channel 2: -20°C ... 100°C]

8.3.8 VA 550 Info

Setup → Sensor Setup → Info

*** Info ***

Production Data

Serial No.: 1234567890 [Details](#)

Cal. Date: 10.01.2013

Sensor Data

Sensor Type: IST 1.8

Max Speed: 92,7 m/s 600m³/h

Max Temp: 100,0 °C

Live Data

Run Time: 2d 21h 23m 12s

Vin: 23,8V Temp: 35,8

[Options](#) [Back](#)

*** Calibration Details ***

Calibration Conditions

Ref. Pressure: 1000.00mbar

Ref. Temperature: 20 °C

Cal. Diameter: 53,1 mm

Cal. Pressure: 6000.00mbar

Cal. Temperature: 23 °C

Cal. Points: 10

[Back](#)

Here you get a brief description of the sensor data incl. the calibration data.


Under **Details**, you are able to see in addition the calibration conditions.

8.4 MBus

8.4.1 Change of communication settings



The communication settings Primary-address and baud rate could be changed directly at the sensor, in case sensor has a display, or with the CS Service software (Order-No. 0554 2007).

Settings → M-Bus



Settings → M-Bus → Adr

Possible inputs are values from 1-255 (Default setting = 1)

With „>“ select the button „Adr“ and confirm it with „OK“.

Select the desired position by pressing the button „△“ and select it with „OK“ button.

Change values by pressing „>“ with step of 1, taking the value by confirming with „OK“.

Move to next position with „>“

Using „CLR“ clears up the complete settings at once.


For saving the changes done press button „Save“ to discard the changes press button „Cancel“.

Leaving the menu with „Back“.

Remark: Secondary address “ID” is not changeable the ID is fixed.

Settings → M-Bus → Baudrate

Possible values are 2400, 4800 and 9600 Baud (Default setting = 2400).




Baudrate change by pressing the button „OK“

For saving the changes done press button „Save“ to discard the changes press button „Cancel“.

Leaving the menu with „Back“.

8.4.2 Coding VIF (Value Information Field)




*** M-Bus ***

Adr 1 Baudrate 2400

ID 123456

☐ Units as String

back



*** M-Bus ***

Adr 1 Baudrate 2400

ID 123456

☒ Units as String

Save Cancel

The Sensor offers two possibilities for coding the Value Information Field (VIF).

- Primary VIF (The units and multiplier correspond to MBus specification 4.8 chapter 8.4.3)
- Plain text VIF ((units are transmitted as ASCII characters. So units that are not included in MBus specification chapter 8.4.3 are possible)
-

Switch to Plain Text VIF by activation of „Units as String“.

8.4.3 Default Settings communication

Primary Address*:	1
ID:	Serial number of Sensor
Baud rate*:	2400
Medium*:	depending on medium (Gas or Compressed Air)
Manufacturer ID:	CSI
VIF coding:	Primary VIF

Both addresses, Primary address and ID, could be searched in the M-Bus system automatically.

8.4.4 Default values transmitted

Value 1 with [Unit]*:	Consumption [m ³]
Value 2 with [Unit]*:	Flow [m ³ /h]
Value 3 with [Unit]*:	Gas temperature [°C]

*All Values could be changed / preset in production or with CS Service software (Order-No. 0554 2007)

9 Supplementary Documentation

- Supplementary Documentation for Ex-Version:

Flow / Consumption Sensor VA 550 Ex / VA5 70 Ex - Ex-Dokumentation



KONFORMITÄTSERKLÄRUNG

DECLARATION OF CONFORMITY

Wir
We

CS Instruments GmbH
Am Oker 28c, 24955 Harrislee

Erklären in alleiniger Verantwortung, dass das Produkt

Declare under our sole responsibility that the product

Verbrauchs-/ Durchflusssensor VA 550

Flow Sensor VA550

den Anforderungen folgender Richtlinien entsprechen:

We hereby declare that above mentioned components comply with requirements of the following EU directives:

Elektromagnetische Verträglichkeit Electromagnetic compatibility	2014/30/EU 2014/30/EC
RoHS (Restriction of certain Hazardous Substances)	2011/65/EC

Angewandte harmonisierte Normen:

Harmonised standards applied:

EMV-Anforderungen EMC requirements	EN 55011: 2011-04 EN 61326-1: 2013-07
---------------------------------------	--


Anbringungsjahr der CE Kennzeichnung: 15

Year of first marking with CE Label: 15

Das Produkt ist mit dem abgebildeten Zeichen gekennzeichnet.
The product is labelled with the indicated mark.



Harrislee, den 19.04.2016


Wolfgang Blessing Geschäftsführer